#### FORM 00414

## ADDENDUM TO SOLICITATION DOCUMENTS

Gadsden County Schools 35 Martin Luther King Jr. Blvd. Quincy, Florida 32351

## Solicitation Addendum No. 1

Date:

5/24/2021

RFP No.

2021-0002

Project Name: HMS Door Replacement Project Phase I

# **NOTICE TO ALL BIDDERS**

The following addendum shall be made part of the Contract Documents and the Bidder shall acknowledge receipt on the Bid Form. It is being issued for the purpose of clarifying the intent of the Contract Documents. Each Bidder is instructed to incorporate this addendum into their Bid Documents and bid accordingly.

#### **PRE-BID QUESTIONS and ANSWERS**

1	Q	I saw that Steelcraft was used in specs for preferred hollow metal manufacturer. We aren't a steelcraft dealer and wanted to confirm that Ceco hollow metal doors and frames can be used instead. I've attached a cutsheet with tech data for the doors and frames.		
	Α	Following the same specifications, Ceco HMD and Frames are an acceptable equal.		
2	Q	Door 804a in the Havana Magnet school calls for a flush door in the construction documents, however the existing door has a full louver. Should door be priced using a full louver or is the door to be flush?		
	Α	Door 804A should be priced as a flush door with no louver.		
3	Q	Are the exterior doors required to have windstorm labels( hurricane labels)		
	A	The intent is for all doors and hardware, only in hardware set No. 9, to be listed and labeled for Hurricane protection as required for shelter compliance.		
4	Q			
	A	The Proposal Due Date has changed from June 7, 2021 to June 8, 2021. A copy of the revised schedule is attached.		
5	Q			
	Α			
6	Q			
	Α			
Preparer's Name 5/24/2021  Date				
Authorizing Agent Date				

NOTE: This document must be signed and included with your Bid

## SCHEDULE OF EVENTS (REVISED 5/24/2021)

**Summary:** A schedule of events shall be established that will govern all action items related to the competitive solicitation process. This schedule shall be strictly maintained.

Failure by any proposer to meet the event schedule will disqualify that proposer from participating in this RFP but does not disqualify that Proposer from participation in other RFPs.

### **Schedule of Events**

Description	Date	Time
Public posting	<u>5/7/2021</u>	<u>8:00 am</u>
Last day for written inquiries	<u>5/21/2021</u>	<u>4:00 pm</u>
Anticipated answers to questions	<u>5/26/2021</u>	<u>5:00 pm</u>
Proposal due date	6/8/2021	<u>1:45 pm</u>
Proposal opening	6/8/2021	<u>2:00 pm</u>
Anticipated start of evaluation	6/8/2021	<u>2:00 pm</u>
Anticipated recommendations to the Board	6/22/2021	<u>6:00 pm</u>

Site visits may be scheduled through the Maintenance office by calling (850) 627-9888.

Recommendation will be made to the Board, providing the proposals have been submitted in accordance with the requirements of this RFP document.