



May 28, 2010

## **Access Control System RFP OPS FM 2013-003**

### **Addendum #1**

Pricing should include electric strikes only.

Proposed systems that have a master shutdown feature should integrate with the mass communication system to offer a tone or recording over said mass communication system.

Access Control should be a stand-alone system that integrates with our camera and telephone systems.

Pricing should include Cat 6 cabling.