



Request for Proposal
Network Cabling, Wireless Access Points and IP cameras
New District Office
RFP Solicitation Number: Tech 2013-005
Addendum 3 – response to questions

- On the cabling please verify plenum or non-plenum. *As specified in the RFP, PLENUM CAT6*
- In the computer lab you said all quad drops. *Correct – quad drops at all locations in the lab*
- How about the rest of the building - single or double drops everywhere else? *Double at all other locations*
- Were icons marked 1 data/ 1 voice, is that to mean there will only be 2 cables at that location? *All drops, except lab, are to be double drops. In case of data/voice, there will be 2 cables pulled and terminated.*