

BID SPECIFICATIONS FOR NEW FUELING SYSTEM

Ozark City Schools Transportation Dept.

860 South Hwy 231 Ozark Al. 36360

1. One new or used ten thousand gal. single wall tank installed.

Bidder should include prices for both tanks. Used tank cannot be more than ten years old and must be cleaned, painted, and have a pressure test prior to install. Tank must be painted white.

2. New Fuel Master Key system w/ 50 keys installed.
3. One new manual duel product/duel pump installed and connected to old diesel tank and new gas tank. Will consider a used gasboy duel product / duel pump system if available.
4. Entire system to be installed into current retention pond.
5. Old thousand gal. tank and old pump to be removed from retention pond area and set aside for future sale.
6. The exterior surface of the 10,000 gal. diesel tank shall be cleaned of foreign material and coated with a corrosion resistant industrial white paint (3 to 5 mils dry film thickness).
7. Bidder must furnish all products and supplies for installation.
8. All work must meet NFPA, State, City, and County codes.
9. Sealed Bids will be opened at 10:00 AM on Sept. 13th.
10. An itemized billing Invoice shall be provided upon completion of entire job.

If you have any questions contact Lee Holland at (334)774-5197

Ext. 3506