

NFPA® 1403

Standard on Live Fire Training Evolutions

2012 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization



Become a
Member

Subscribe
to the



Register for
Seminars, Webinars,
and Online Courses

Visit the
NFPA Catalog

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA® codes, standards, recommended practices, and guides (“NFPA Documents”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Documents.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Documents. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Documents available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Documents. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Document. The users of NFPA Documents bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Documents.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Document may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Documents are copyrighted by the NFPA. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Documents and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02169-7471; email: stds_admin@nfpa.org

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2012 National Fire Protection Association®. All Rights Reserved.

NFPA® 1403

Standard on

Live Fire Training Evolutions

2012 Edition

This edition of NFPA 1403, *Standard on Live Fire Training Evolutions*, was prepared by the Technical Committee on Fire Service Training. It was issued by the Standards Council on December 13, 2011, with an effective date of January 2, 2012, and supersedes all previous editions.

This edition of NFPA 1403 was approved as an American National Standard on January 2, 2012.

Origin and Development of NFPA 1403

The ongoing training of fire fighters is the cornerstone of good fire protection in today's world. However, the benefits derived from live fire training can be negated by the injuries and deaths suffered by fire fighters under unsafe and poorly supervised training conditions.

Following a tragic training accident in 1982, which resulted in the deaths of two fire fighters, the Committee on Fire Service Training was urged to address the issue of live fire training evolutions in structures. The committee proceeded to develop NFPA 1403 in order to provide recognized safe practices for conducting such training evolutions.

The first edition, titled *Live Fire Training Evolutions in Structures*, was issued in 1986. It was well received and served as the basis for live fire training evolutions throughout the United States. The document was updated in a 1992 edition. In the 1997 revision, the committee combined NFPA 1403 and NFPA 1406, *Outside Live Fire Training Evolutions*, into a single document.

The committee appointed a task group to review the functionality of the 1997 edition in preparation for the 2002 revision. The task group recommended a general updating of the standard. Changes were made to reflect increased experience with live fire training evolutions. The previous numbering of chapters and paragraphs was changed to reflect requirements in the 2000 edition of the *Manual of Style for NFPA Technical Committee Documents*.

The 2007 edition updated training requirements for live fire training structures, exterior props, and Class B fires. This edition also contained several editorial changes.

For the 2012 edition, the committee has added a new Chapter 4, to address general requirements to which all live fire training evolutions must adhere for safety, and that were previously located in individual chapters. The committee has also further clarified the requirements for emergency medical services, allowable types of Class A products, instructor duties, and the role of the fire control team. A new requirement has been added that mandates that each burn room have a burn plan in place to limit building damage and injuries to fire fighters. The inspection and maintenance requirements for live fire training structures have also been revised.

Technical Committee on Fire Service Training

William E. Peterson, Chair
Plano, TX [SE]

Rep. International Fire Marshals Association

Wesley E. Barbour, CrossBar International LLC,
NY [SE]

Roger W. Bassett, R. W. Bassett & Associates, IL [SE]

John M. Best, John Jay College of Criminal Justice,
MD [U]

John P. Brown, Nassau County Fire Service Academy, NY
[U]

W. Edward Buchanan, Jr., Hanover Fire & EMS,
VA [U]

Rick Egelin, Fireblast 451 Incorporated, CA [M]

William E. Glover, High Temperature Linings (HTL),
VA [M]

Larry D. Hughes, North Carolina Department of
Insurance, NC [E]

Cortez Lawrence, U.S. Department of Homeland
Security, MD [SE]

Roger M. LeBoeuf, Elliott, LeBoeuf & McElwain, VA [SE]

Lavarn E. Lucas, Hilton Head Island Fire & Rescue,
SC [E]

Daniel Madrzykowski, National Institute of Standards
& Technology, MD [RT]

F. Patrick Marlatt, Maryland Fire and Rescue Institute,
MD [E]

Kevin Munson, Jr., West Hartford Fire Department,
CT [U]

Brent Norwine, CAL-FIRE/Riverside County Fire
Department, CA [U]

J. Ron Peddy, Texas Engineering Extension Service,
TX [U]

James E. Podolske, Jr., U.S. Department of the Air Force,
FL [U]

Kenneth W. Richards, Jr., Old Mystic Fire Department,
CT [E]

Daniel N. Rossos, Portland Fire & Rescue, OR [E]

Daniel D. Shaw, Fairfax County Fire and Rescue
Department, MD [U]

Gary A. Simpson, E. D. Bullard Company, KY [M]

Frederick M. Stowell, Fire Protection Publications,
OK [M]

Rep. International Fire Service Training Association

Richard Verlinda, Seattle Fire Department, WA [E]

Phil Welch, Gastonia Fire Department, NC [U]

Steven J. Williamson, UTC/Kidde Fire Trainers, Inc.,
NJ [M]

Michael L. Young, Volunteer Firemen's Insurance
Services, Inc., PA [I]

Alternates

Adam M. Barowy, National Institute of Standards
& Technology, MD [RT]

(Alt. to D. Madrzykowski)

George F. Hall, International Fire Associates Consulting,
LLC, FL [U]

(Alt. to J. E. Podolske, Jr.)

William F. Jenaway, Volunteer Firemen's Insurance
Services, Inc., PA [I]

(Alt. to M. L. Young)

Steven C. Luftig, UTC/Kidde Fire Trainers, Inc.,
NJ [M]

(Alt. to S. J. Williamson)

Denis G. Onieal, U.S. Department of Homeland Security,
MD [SE]

(Alt. to C. Lawrence)

Michael A. Wieder, Fire Protection Publications,
OK [M]

(Alt. to F. M. Stowell)

Nonvoting

Edward W. Bent, Sacramento, CA
(Member Emeritus)

Steven F. Sawyer, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for all fire service training techniques, operations, and procedures to develop maximum efficiency and proper utilization of available personnel. Such activities can include training guides for fire prevention, fire suppression, and other missions for which the fire service has responsibility.



Contents

Chapter 1 Administration	1403- 4	Chapter 5 Acquired Structures	1403- 9
1.1 Scope	1403- 4	5.1 Structures and Facilities	1403- 9
1.2 Purpose	1403- 4	5.2 Hazards	1403- 9
1.3 Application	1403- 4	5.3 Utilities	1403-10
Chapter 2 Referenced Publications	1403- 4	5.4 Exits	1403-10
2.1 General	1403- 4	5.5 Rapid Intervention Crew (RIC)	1403-10
2.2 NFPA Publications	1403- 4	Chapter 6 Gas-Fired Live Fire Training Structures	1403-10
2.3 Other Publications	1403- 4	6.1 Structures and Facilities	1403-10
2.4 References for Extracts in Mandatory Sections	1403- 4	6.2 Inspection and Testing	1403-10
Chapter 3 Definitions	1403- 4	Chapter 7 Non-Gas-Fired Live Fire Training Structures	1403-10
3.1 General	1403- 4	7.1 Structures and Facilities	1403-10
3.2 NFPA Official Definitions	1403- 5	7.2 Inspection and Testing	1403-10
3.3 General Definitions	1403- 5	7.3 Sequential Live Fire Burn Evolutions	1403-11
Chapter 4 General	1403- 5	Chapter 8 Exterior Live Fire Training Props	1403-11
4.1 Application	1403- 5	8.1 Props, Structures, and Facilities	1403-11
4.2 Permits	1403- 5	8.2 Inspection and Maintenance	1403-11
4.3 Student Prerequisites	1403- 6	Chapter 9 Reports and Records	1403-11
4.4 Safety Officer	1403- 6	9.1 General	1403-11
4.5 Extreme Weather	1403- 6	Annex A Explanatory Material	1403-12
4.6 Instructor in Charge and Instructors	1403- 6	Annex B Live Fire Evolution Sample Checklist	1403-20
4.7 Fire Control Team	1403- 6	Annex C Responsibilities of Personnel	1403-20
4.8 Personal Protective Clothing	1403- 7	Annex D Heat Exhaustion and Heat Stroke in Training	1403-20
4.9 Communication	1403- 7	Annex E Informational References	1403-24
4.10 Emergency Medical Services (EMS)	1403- 7	Index	1403-25
4.11 Water Supply	1403- 7		
4.12 Fuel Materials	1403- 7		
4.13 Parking/Staging	1403- 8		
4.14 Visitors and Spectators	1403- 8		
4.15 Preburn Plan/Briefing	1403- 8		

NFPA 1403
Standard on
Live Fire Training Evolutions
2012 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition. Where one or more complete paragraphs have been deleted, the deletion is indicated by a bullet (•) between the paragraphs that remain.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex E. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex E.

Chapter 1 Administration

1.1* Scope.

1.1.1 This standard shall contain the minimum requirements for training all fire suppression personnel engaged in fire-fighting operations under live fire conditions.

1.1.2 The minimum requirements for training shall comprise a basic system that can be adapted to local conditions to serve as a standard mechanism for live fire training.

1.2* Purpose.

1.2.1 The purpose of this standard shall be to provide a process for conducting live fire training evolutions to ensure that they are conducted in safe facilities and that the exposure to health and safety hazards for the fire fighters receiving the training is minimized.

1.2.2 Live fire training is intended to provide the safest and best experience possible under both realistic and controlled circumstances.

1.3 Application.

1.3.1 All live fire training shall be conducted in compliance with the current edition of this standard.

1.3.2 Procedures for live fire training evolutions that involve ground cover or wildland fires shall not be covered in this standard.

1.3.3* Procedures for suppression of fires set for the sole purpose of training individuals for fire cause and origin investigation shall not be covered in this standard.

1.3.4 Live fire training shall only be conducted using standard operating procedures (SOPs) developed by the authority having jurisdiction in compliance with this standard.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 30, *Flammable and Combustible Liquids Code*, 2012 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2011 edition.

NFPA 59, *Utility LP-Gas Plant Code*, 2012 edition.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 2008 edition.

NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*, 2012 edition.

NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*, 2012 edition.

NFPA 1407, *Standard for Training Fire Service Rapid Intervention Crews*, 2010 edition.

NFPA 1971, *Standard on Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*, 2007 edition.

NFPA 1975, *Standard on Station/Work Uniforms for Emergency Services*, 2009 edition.

NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services*, 2007 edition.

NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*, 2007 edition.

2.3 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 2008 edition.

NFPA 1410, *Standard on Training for Initial Emergency Scene Operations*, 2010 edition.

NFPA 1500, *Standard on Fire Department Occupational Safety and Health Program*, 2007 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.2 Shall. Indicates a mandatory requirement.

3.2.3 Should. Indicates a recommendation or that which is advised but not required.

3.2.4 Standard. A document, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an appendix or annex, footnote, or fine-print note and are not to be considered a part of the requirements of a standard.

3.3 General Definitions.

3.3.1 Acquired Prop. A piece of equipment such as an automobile that was not designed for burning but is used for live fire training evolutions.

3.3.2 Backdraft. A deflagration resulting from the sudden introduction of air into a confined space containing oxygen-deficient products of incomplete combustion.

3.3.3 Combustible. Capable of burning, generally in air under normal conditions of ambient temperature and pressure, unless otherwise specified. Combustion can occur in cases where an oxidizer other than oxygen in air is present (e.g., chlorine, fluorine, or chemicals containing oxygen in their structure).

3.3.4 Conduction. Heat transfer to another body or within a body by direct contact.

3.3.5 Convection. Heat transfer by circulation within a medium such as a gas or a liquid.

3.3.6 Deflagration. Propagation of a combustion zone at a velocity that is less than the speed of sound in the unreacted medium.

3.3.7 Demonstration. The act of showing a skill.

3.3.8 Emergency Medical Services. The provision of treatment, such as first aid, cardiopulmonary resuscitation, basic life support, advanced life support, and other pre-hospital procedures, including ambulance transportation, to patients. [1500, 2007]

3.3.9 Evolution. A set of prescribed actions that result in an effective fireground activity. [1410, 2010]

3.3.10 Flameover (Rollover.) The condition in which unburned fuel (pyrolysate) from the originating fire has accumulated in the ceiling layer to a sufficient concentration (i.e., at or above the lower flammable limit) that it ignites and burns. Flameover can occur without ignition of or prior to the ignition of other fuels separate from the origin.

3.3.11 Flashover. A transition phase in the development of a compartment fire in which surfaces exposed to thermal radiation reach ignition temperature more or less simultaneously and fire spreads rapidly throughout the space, resulting in full room involvement or total involvement of the compartment or enclosed space.

3.3.12 Fuel Load. The total quantity of combustible contents of a building, space, or fire area, including interior finish and trim, expressed in heat units or the equivalent weight in wood.

3.3.13 Instructor. An individual qualified by the authority having jurisdiction to deliver fire-fighter training, who has the training and experience to supervise students during live fire training evolutions.

3.3.14 Instructor-in-Charge. An individual qualified as an instructor and designated by the authority having jurisdiction to be in charge of the live fire training evolution.

3.3.15 Live Fire. Any unconfined open flame or device that can propagate fire to the building, structure, or other combustible materials.

3.3.16 Participant. Any student, instructor, safety officer, visitor, or other person who is involved in the live fire training evolution within the operations area.

3.3.17 Personal Accountability Report (PAR). A report requested by and communicated to the incident commander from fire crews operating at a scene as to their location and situation.

3.3.18 Personal Protective Clothing. The full complement of garments fire fighters are normally required to wear while on emergency scene, including turnout coat, protective trousers, fire-fighting boots, fire-fighting gloves, a protective hood, and a helmet with eye protection. [1001, 2008]

3.3.19 Personal Protective Equipment. Consists of full personal protective clothing, plus a self-contained breathing apparatus (SCBA) and a personal alert safety system (PASS) device. [1001, 2008]

3.3.20 Pyrolysate. Product of decomposition through heat; a product of a chemical change caused by heating.

3.3.21 Radiation. Heat transfer by way of electromagnetic energy.

3.3.22 Safety Officer. An individual appointed by the authority having jurisdiction as qualified to maintain a safe working environment at all live fire training evolutions.

3.3.23 Student. Any person who is present at the live fire training evolution for the purpose of receiving training.

3.3.24 Training Structure.

3.3.24.1 Acquired Structure. A building or structure acquired by the authority having jurisdiction from a property owner for the purpose of conducting live fire training evolutions.

3.3.24.2* Live Fire Training Structure. A structure specifically designed for conducting live fire training evolutions on a repetitive basis.

3.3.25 Ventilation-Controlled Fire. A fire in which the heat release rate or growth is controlled by the amount of air available to the fire.

Chapter 4 General

4.1 Application. All live fire training evolutions shall comply with this chapter and the appropriate chapter for the type of training being performed.

4.1.1 Strict safety practices shall be applied to all structures selected for live fire training evolutions.

4.2 Permits.

4.2.1 All required permits to conduct live fire training evolutions shall be obtained.

4.2.2 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the authority having jurisdiction (AHJ) upon the request of those agencies.

4.2.3 The runoff from live fire shall comply with the requirements of the AHJ.

4.3 Student Prerequisites.

4.3.1* Prior to being permitted to participate in live fire training evolutions, the student shall have received training to meet the minimum job performance requirements for Fire Fighter I in NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, related to the following subjects:

- (1) Safety
- (2) Fire behavior
- (3) Portable extinguishers
- (4) Personal protective equipment
- (5) Ladders
- (6) Fire hose, appliances, and streams
- (7) Overhaul
- (8) Water supply
- (9) Ventilation
- (10) Forcible entry
- (11) Building construction

4.3.2* Students participating in a live fire training evolution who have received the required minimum training from other than the AHJ shall not be permitted to participate in any live fire training evolution without first presenting prior written evidence of having successfully completed the prescribed minimum training to the levels specified in 4.3.1.

4.4 Safety Officer.

4.4.1 A safety officer shall be appointed for all live fire training evolutions.

4.4.2* All live fire training instructors and safety officers shall be trained on the application of the requirements contained in this standard.

4.4.3 The safety officer shall have the authority, regardless of rank, to intervene and control any aspect of the operations when, in his or her judgment, a potential or actual danger, potential for accident, or unsafe condition exists.

4.4.4 The responsibilities of the safety officer shall include, but not be limited to, the following:

- (1) Prevention of unsafe acts
- (2) Elimination of unsafe conditions

4.4.5 The safety officer shall provide for the safety of all persons on the scene, including students, instructors, visitors, and spectators.

4.4.6 The safety officer shall not be assigned other duties that interfere with safety responsibilities.

4.4.7 The safety officer shall be knowledgeable in the operation and location of safety features available for the live fire training structure or prop, such as emergency shutoff switches, gas shutoff valves, and evacuation alarms.

4.4.8* Additional safety personnel, as deemed necessary by the safety officer, shall be located to react to any unsafe or threatening situation or condition.

4.5* Extreme Weather. The training session shall be curtailed, postponed, or canceled, as necessary, to reduce the risk of injury or illness caused by extreme weather conditions.

4.6 Instructor in Charge and Instructors.

4.6.1 The instructor-in-charge shall have received training to meet the minimum job performance requirements for Fire Instructor I in NFPA 1041, *Standard for Fire Service Instructor Professional Qualifications*.

4.6.2 The instructor-in-charge shall be responsible for full compliance with this standard.

4.6.3 It shall be the responsibility of the instructor-in-charge to coordinate overall fireground activities to ensure correct levels of safety.

4.6.4 The instructor-in-charge shall assign the following personnel:

- (1) One instructor to each functional crew, each of which shall not exceed five students
- (2) One instructor to each backup line
- (3) One additional instructor for each additional functional assignment

4.6.5 The instructor-in-charge shall provide for rest and rehabilitation of participants operating at the scene, including any necessary medical evaluation and treatment, food and fluid replenishment, and relief from climatic conditions. (*See Annex D.*)

4.6.5.1* Instructors shall be rotated through duty assignments.

4.6.6 All instructors shall be qualified by the AHJ to deliver live fire training.

4.6.7 Additional instructors shall be designated when factors such as extreme temperatures or large groups are present, and classes of long duration are planned.

4.6.8 Prior to the ignition of any fire, instructors shall ensure that all protective clothing and equipment specified in this chapter are being worn according to manufacturer's instructions.

4.6.9 Instructors shall take a personal accountability report (PAR) when entering and exiting the structure or prop during an actual attack evolution conducted in accordance with this standard.

4.6.10 Instructors shall monitor and supervise all assigned students during the live fire training evolution.

4.6.11 Awareness of weather conditions, wind velocity, and wind direction shall be maintained, including a final check for possible changes in weather conditions immediately before actual ignition.

4.6.12 Training Instructors on How to Use Specialty Props.

4.6.12.1 The instructors and the safety officer responsible for conducting live fire training evolutions with a gas-fueled training system or with other specialty props (such as flashover simulator) shall be trained in the complete operation of the system and the props.

4.6.12.2 The training of instructors and the safety officer shall be performed by an individual authorized by the gas-fueled training system and specialty prop manufacturer or by others qualified to perform this type of training.

4.7 Fire Control Team

4.7.1 A fire control team shall consist of a minimum of two personnel.

4.7.1.1 One person who is not a student or safety officer shall be designated as the "ignition officer" to ignite, maintain, and control the materials being burned.



4.7.1.1.1 The ignition officer shall be a member of the fire control team.

4.7.1.2* One member of the fire control team shall be in the area to observe the ignition officer ignite and maintain the fire, and to recognize, report, and respond to any adverse conditions.

4.7.2 The decision to ignite the training fire shall be made by the instructor-in-charge in coordination with the safety officer.

4.7.3 The fire shall be ignited by the ignition officer.

4.7.4 The fire control team shall wear full personal protective clothing, including SCBA, when performing this control function.

4.7.5 A charged hose line shall be available when the fire control team is igniting or tending to any fire.

4.7.6 Fires shall not be ignited without an instructor visually confirming that the flame area is clear of personnel being trained.

4.8 Personal Protective Clothing.

4.8.1 All students, instructors, safety personnel, and other personnel shall wear all protective clothing and equipment specified in this chapter according to manufacturer's instructions whenever they are involved in any evolution or fire suppression operation during the live fire training evolution.

4.8.2* All participants shall be inspected by the safety officer prior to entry into a live fire training evolution to ensure that the protective clothing and SCBA are being worn correctly and are in serviceable condition.

4.8.3 Protective coats, trousers, hoods, footwear, helmets, and gloves shall have been manufactured to meet the requirements of NFPA 1971, *Standard on Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*.

4.8.4 SCBA shall have been manufactured to meet the requirements of NFPA 1981, *Standard on Open-Circuit Self-Contained Breathing Apparatus (SCBA) for Emergency Services*.

4.8.5* Where station or work uniforms are worn by any participant, the station or work uniform shall have been manufactured to meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Emergency Services*.

4.8.6 Personal alarm devices shall have been manufactured to meet the requirements of NFPA 1982, *Standard on Personal Alert Safety Systems (PASS)*.

4.8.7* All students, instructors, safety personnel, and other personnel participating in any evolution or operation of fire suppression during the live fire training evolution shall breathe from an SCBA air supply whenever they operate under one or more of the following conditions:

- (1) In an atmosphere that is oxygen deficient or contaminated by products of combustion, or both
- (2) In an atmosphere that is suspected of being oxygen deficient or contaminated by products of combustion, or both
- (3) In any atmosphere that can become oxygen deficient, contaminated, or both
- (4) Below ground level

4.9 Communication.

4.9.1 A method of fireground communications shall be established to enable coordination among the incident commander,

the interior and exterior sectors, the safety officer, and external requests for assistance.

4.9.2* A building evacuation plan shall be established, including an evacuation signal to be demonstrated to all participants in an interior live fire training evolution.

4.10 Emergency Medical Services (EMS).

4.10.1 Basic life support (BLS) emergency medical services shall be available on site to handle injuries.

4.10.1.1 For acquired structures, BLS emergency medical services with transport capabilities shall be available on site to handle injuries.

4.10.2 A parking area for an ambulance or an emergency medical services vehicle shall be designated and located where it will facilitate a prompt response in the event of personal injury to participants in the evolution.

4.10.3 Written reports shall be completed and submitted on all injuries and on all medical aid rendered.

4.11* Water Supply.

4.11.1 The instructor-in-charge and the safety officer shall determine the rate and duration of waterflow necessary for each individual live fire training evolution, including the water necessary for control and extinguishment of the training fire, the water supply necessary for backup line(s) to protect personnel, and any water needed to protect exposed property.

4.11.2 Each hose line and backup line(s) shall be capable of delivering a minimum of 95 gpm (360 L/min).

4.11.3 Backup line(s) shall be provided to ensure protection for personnel on training attack lines.

4.11.4 The minimum water supply and delivery for the live fire training evolutions shall meet the criteria identified in NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*.

4.11.5 A minimum reserve of additional water in the amount of 50 percent of the fire flow demand, determined in accordance with 4.11.1, shall be available to handle exposure protection or unforeseen situations.

4.11.5.1 The requirements of 4.11.5 do not apply to permanently sited gas-fueled training systems.

4.11.6* Except under the conditions of 4.11.6.1, separate water sources shall be utilized for the supply of attack lines and backup lines in order to preclude the loss of both water supply sources at the same time.

4.11.6.1* A single water source shall be sufficient at a training center facility where the water system has been engineered to provide adequate volume for the evolutions conducted and a backup power source or backup pumps, or both, are in place to ensure an uninterrupted supply in the event of a power failure or malfunction.

4.11.7 There shall be room provided around all props so that there is space for all attack line(s) as well as backup line(s) to operate freely.

4.12 Fuel Materials.

4.12.1* The fuels that are utilized in live fire training evolutions shall only be wood products.

4.12.1.1 Fuel-fired buildings and props are permitted to use the appropriate fuels for the design of the building or prop.

4.12.2 Pressure-treated wood, rubber, plastic, polyurethane foam, upholstered furniture, and chemically treated or pesticide-treated straw or hay shall not be used.

4.12.3 Flammable or combustible liquids, as defined in NFPA 30, *Flammable and Combustible Liquids Code*, shall not be used in live fire training evolutions.

4.12.3.1 Combustible liquid with a flash point above 100°F (38°C) shall be permitted to be used in a live fire training structure or prop that has been specifically engineered to accommodate a defined quantity of the fuel.

4.12.4 Unidentified materials, such as debris found in or around the structure or prop that could burn in unanticipated ways, react violently, or create environmental or health hazards, shall not be used.

4.12.5 Propane lighters, butane lighters, fuses (safety flares), kitchen-type matches, and similar devices are permitted to be used to ignite training fires if the device is removed immediately after ignition of the training fire.

4.12.6* Fuel materials shall be used only in the amounts necessary to create the desired fire size.

4.12.7 The fuel load shall be limited to avoid conditions that could cause an uncontrolled flashover or backdraft.

4.12.8* The instructor-in-charge and the safety officer shall assess the selected fire room environment for factors that can affect the growth, development, and spread of fire.

4.12.9* The instructor-in-charge and the safety officer shall document fuel loading, including all of the following:

- (1) Fuel material
- (2) Wall and floor coverings and ceiling materials
- (3) Type of construction of the structure, including type of roof and combustible void spaces
- (4) Dimensions of the room

4.12.10* The training exercise shall be stopped immediately when the instructor-in-charge or the safety officer determines through ongoing assessment that the combustible nature of the environment represents a potential hazard.

4.12.10.1 An exercise stopped as a result of an assessed hazard according to 4.12.10 shall continue only when actions have been taken to reduce the hazard.

4.12.11* The use of flammable gas, such as propane and natural gas, shall be permitted only in live fire training structures specifically designed for their use.

4.12.11.1 Liquefied versions of the gases specified in 4.12.11 shall not be permitted inside the live fire training structure.

4.12.11.2* All props that use pressure to move fuel to the fire shall be equipped with remote fuel shutoffs outside of the safety perimeter but within sight of the prop and the entire field of attack for the prop.

4.12.11.3 During the entire time the prop is in use, the remote shutoff shall be continuously attended by safety personnel who are trained in its operation and who have direct communications with the safety officer and instructors.

4.12.11.4 Liquefied petroleum gas props shall be equipped with all safety features as described in NFPA 58, *Liquefied Petroleum Gas Code*, and NFPA 59, *Utility LP-Gas Plant Code*.

4.12.11.5 Where the evolution involves the failure of a safety feature, the failed part shall be located downstream from the correctly functioning safety feature.

4.12.11.6 Where flammable or combustible liquids are used, measures shall be taken to prevent runoff from contaminating the surrounding area.

4.12.11.6.1 There shall be oil separators for cleaning the runoff water.

4.12.11.7* Vehicles used as props for live fire training shall have all fluid reservoirs, tanks, shock absorbers, drive shafts, and other gas-filled closed containers removed, vented, or drained prior to any ignition.

4.12.11.8 For flammable metal fires, there shall be a sufficient quantity of the proper extinguishing agent available so that all attack crews have the required supply as well as a 150 percent reserve for use by the backup crews.

4.12.11.9 All possible sources of ignition, other than those that are under the direct supervision of the ignition officer, shall be removed from the operations area.

4.13 Parking/Staging.

4.13.1 Areas for the staging, operating, and parking of fire apparatus that are used in the live fire training evolution shall be designated.

4.13.2 An area for parking fire apparatus and vehicles that are not a part of the evolution shall be designated so as not to interfere with fireground operations.

4.13.3 If any of the apparatus described in 4.13.2 is in service to respond to an emergency, it shall be located in an area that will facilitate a prompt response.

4.13.4 Where required or necessary, parking areas for police vehicles or for the press shall be designated.

4.13.5 Ingress and egress routes shall be designated, identified, and monitored during the training evolutions to ensure their availability in the event of an emergency.

4.14 Visitors and Spectators.

4.14.1 All spectators shall be restricted to an area outside the operations area perimeter established by the safety officer.

4.14.2 Control measures shall be posted to indicate the perimeter of the operations area.

4.14.3 Visitors who are allowed within the operations area perimeter shall be escorted at all times.

4.14.4 Visitors who are allowed within the operations area perimeter shall be equipped with and shall wear appropriate protective clothing.

4.14.5 Control measures shall be established to keep pedestrian traffic in the vicinity of the training site clear of the operations area of the live burn.

4.15 Preburn Plan/Briefing.

4.15.1 A preburn plan shall be prepared and shall be utilized during the preburn briefing sessions.

4.15.1.1 All features of the training areas shall be indicated on the preburn plan.

4.15.2 Prior to conducting actual live fire training evolutions, a preburn briefing session shall be conducted by the instructor-in-charge with the safety officer for all participants.

4.15.3 All facets of each evolution to be conducted shall be discussed.

4.15.4 Assignments shall be made for all crews participating in the training session.

4.15.5 The location of the manikin shall not be required to be disclosed, provided that the possibility of victims is discussed in the preburn briefing.

4.15.6 Prior to conducting any live fire training, all participants shall have a knowledge of and familiarity with the prop or props being used for the evolution.

4.15.7 Prior to conducting any live fire training, all participants shall be required to conduct a walk-through of the acquired structure, burn building, or prop in order to have a knowledge of and familiarity with the layout of the acquired structure, building, or prop and to facilitate any necessary evacuation.

4.15.8 Property adjacent to the training site that could be affected by the smoke from the live fire training evolution, such as railroads, airports or heliports, and nursing homes, hospitals, or other similar facilities, shall be identified.

4.15.8.1 The persons in charge of the properties described in 4.15.8 shall be informed of the date and time of the evolution.

4.15.9 Streets or highways in the vicinity of the training site shall be surveyed for potential effects from live fire training evolutions.

4.15.9.1* Safeguards shall be taken to eliminate possible hazards to motorists.

the method of returning the property to the owner shall be put in writing and shall be acknowledged by the owner of the structure.

5.1.8* Proof of insurance cancellation or a signed statement of nonexistence of insurance shall be provided by the owner of the structure prior to acceptance for use of the acquired structure by the AHJ.

5.1.9 The permits specified in this chapter shall be provided to outside, contract, or other separate training agencies by the AHJ upon the request of those agencies.

5.1.10 A search of the acquired structure shall be conducted to ensure that no unauthorized persons, animals, or objects are in the acquired structure immediately prior to ignition.

5.1.11 No person(s) shall play the role of a victim inside the acquired structure.

5.1.12 Only one fire at a time shall be permitted within an acquired structure.

5.2 Hazards.

5.2.1 In preparation for live fire training, an inspection of the structure shall be made to determine that the floors, walls, stairs, and other structural components are capable of withstanding the weight of contents, participants, and accumulated water.

5.2.2* All hazardous storage conditions shall be removed from the structure or neutralized in such a manner as to not present a safety problem during use of the structure for live fire training evolutions.

5.2.3 Closed containers and highly combustible materials shall be removed from the structure.

5.2.3.1 Oil tanks and similar closed vessels that cannot be removed shall be vented to prevent an explosion or overpressure rupture.

5.2.3.2 Any hazardous or combustible atmosphere within the tank or vessel shall be rendered inert.

5.2.4 All hazardous structural conditions shall be removed or repaired so as to not present a safety problem during use of the structure for live fire training evolutions.

5.2.4.1 Floor openings shall be covered to be made structurally sound.

5.2.4.2 Missing stair treads and rails shall be repaired or replaced.

5.2.4.3 Dangerous portions of any chimney shall be removed.

5.2.4.4 Holes in walls and ceilings shall be patched.

5.2.4.5* Roof ventilation openings that are normally closed but can be opened in the event of an emergency shall be permitted to be utilized.

5.2.4.6* Low-density combustible fiberboard and other highly combustible interior finishes shall be removed.

5.2.4.7* Extraordinary weight above the training area shall be removed.

5.2.5* All hazardous environmental conditions shall be removed before live fire training evolutions are conducted in the structure.

Chapter 5 Acquired Structures

5.1 Structures and Facilities.

5.1.1* Any acquired structure that is considered for a structural fire training exercise shall be prepared for the live fire training evolution.

5.1.1.1 Buildings that cannot be made safe as required by this chapter shall not be utilized for interior live fire training evolutions.

5.1.2 Adjacent buildings or property that might become involved shall be protected or removed.

5.1.3* Preparation shall include application for and receipt of required permits and permissions.

5.1.4* Ownership of the acquired structure shall be determined prior to its acceptance by the AHJ.

5.1.5 Evidence of clear title shall be required for all structures acquired for live fire training evolutions.

5.1.6* Written permission shall be secured from the owner of the structure in order for the fire department to conduct live fire training evolutions within the acquired structure.

5.1.7 A clear description of the anticipated condition of the acquired structure at the completion of the evolution(s) and

5.2.5.1 All forms of asbestos deemed hazardous shall be removed by an approved manner and documentation provided to the AHJ.

5.2.6 Debris creating or contributing to unsafe conditions shall be removed.

5.2.7 Any toxic weeds, insect hives, or vermin that could present a potential hazard shall be removed.

5.2.8 Trees, brush, and surrounding vegetation that create a hazard to participants shall be removed.

5.2.9 Combustible materials, other than those intended for the live fire training evolution, shall be removed or stored in a protected area to preclude accidental ignition.

5.3 Utilities.

5.3.1 Utilities shall be disconnected.

5.3.2 Utility services adjacent to the live burn site shall be removed or protected.

5.4 Exits.

5.4.1 Exits from the acquired structure shall be identified and evaluated prior to each training burn.

5.4.2 Participants of the live fire training shall be made aware of exits from the acquired structure prior to each training burn.

5.4.3 Fires shall not be located in any designated exit paths.

5.5 Rapid Intervention Crew (RIC). A RIC trained in accordance with NFPA 1407, *Standard for Training Fire Service Rapid Intervention Crews*, shall be provided during a live fire training evolution.

Chapter 6 Gas-Fired Live Fire Training Structures

6.1 Structures and Facilities.

6.1.1 This section pertains to all interior spaces where gas-fired live fire training exercises occur.

6.1.2 Live fire training structures shall be left in a safe condition upon completion of live fire training evolutions.

6.1.3 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the training exercises.

6.1.4 Flammable gas fires shall not be ignited manually.

6.2 Inspection and Testing.

6.2.1* Live fire training structures shall be inspected visually for damage prior to live fire training evolutions.

6.2.1.1* Damage shall be documented and the building owner or AHJ shall be notified.

6.2.2 Where the live fire training structure damage is severe enough to affect the safety of the participants, training shall not be permitted.

6.2.3 All doors, windows and window shutters, railings, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.

6.2.4 All safety devices, such as thermal sensors, combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

6.2.5 The instructors shall run the training system prior to exposing students to live flames in order to ensure the correct operation of devices such as the gas valves, flame safeguard units, agent sensors, combustion fans, and ventilation fans.

6.2.6* The structural integrity of the live fire training structure shall be evaluated and documented annually by the building owner or AHJ.

6.2.6.1 If visible structural defects are found, such as cracks, rust, spalls, or warps in structural floors, columns, beams, walls, or metal panels, the building owner shall have a follow-up evaluation conducted by a licensed professional engineer with live fire training structure experience and expertise, or by another competent professional as determined by the building owner or AHJ.

6.2.7* The structural integrity of the live fire training structure shall be evaluated and documented by a licensed professional engineer with live fire training structure experience and expertise, or by another competent professional as determined by the AHJ, at least once every 10 years, or more frequently if determined to be required by the evaluator.

6.2.8* All structures constructed with calcium aluminate refractory structural concrete shall be inspected by a structural engineer with expertise in live fire training structures every 3 years.

6.2.8.1 The structural inspection shall include removal of concrete core samples from the structure to check for delaminations within the concrete.

6.2.9* Part of the live fire training structure evaluation shall include, at least once every 10 years, the removal and reinstallation of a representative area of thermal linings (if any) to inspect the hidden conditions behind the linings.

Chapter 7 Non-Gas-Fired Live Fire Training Structures

7.1 Structures and Facilities.

7.1.1 This section pertains to all interior spaces where non-gas-fired live fire training exercises occur.

7.1.2 Live fire training structures shall be left in a safe condition upon completion of live fire training evolutions.

7.1.3 Debris hindering the access or egress of fire fighters shall be removed prior to the beginning of the training exercises.

7.2 Inspection and Testing.

7.2.1* Live fire training structures shall be inspected visually for damage prior to live fire training evolutions.

7.2.1.1* Damage shall be documented, and the building owner or AHJ shall be notified.

7.2.2 Where the live fire training structure damage is severe enough to affect the safety of the participants, training shall not be permitted.

7.2.3 All doors, windows and window shutters, railings, roof scuttles and automatic ventilators, mechanical equipment, lighting, manual or automatic sprinklers, and standpipes necessary for the live fire training evolution shall be checked and operated prior to any live fire training evolution to ensure they operate correctly.

7.2.4 All safety devices, such as thermal sensors, oxygen and toxic and combustible gas monitors, evacuation alarms, and emergency shutdown switches, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

7.2.5* The structural integrity of the live fire training structure shall be evaluated and documented annually by the building owner or AHJ.

7.2.5.1 If visible structural defects are found, such as cracks, rust, spalls, or warps in structural floors, columns, beams, walls, or metal panels, the building owner shall have a follow-up evaluation conducted by a licensed professional engineer with live fire training structure experience and expertise or by another competent professional as determined by the AHJ.

7.2.6* The structural integrity of the live fire training structure shall be evaluated and documented by a licensed professional engineer with live fire training structure experience and expertise or by another competent professional as determined by the AHJ at least once every 5 years or more frequently if determined to be required by the evaluator.

7.2.7* All structures constructed with calcium aluminate refractory structural concrete shall be inspected by a structural engineer with expertise in live fire training structures every 3 years.

7.2.7.1 The structural inspection shall include removal of concrete core samples from the structure to check for delaminations within the concrete.

7.2.8* Part of the live fire training structure evaluation shall include, once every five years, the removal and reinstallation of a representative area of thermal linings (if any) to allow inspections of the conditions hidden behind the linings.

7.3 Sequential Live Fire Burn Evolutions.

7.3.1 The AHJ shall develop and utilize a safe live fire training action plan when multiple sequential burn evolutions are to be conducted per day in each burn room.

7.3.2 A burn sequence matrix chart shall be developed for the burn rooms in a live fire training structure.

7.3.2.1 The burn sequence matrix chart shall include the maximum fuel loading per evolution and maximum number of sequential live fire evolutions that can be conducted per day in each burn room.

7.3.3* The burn sequence for each room shall define the maximum fuel load that can be used for the first burn and each successive burn.

7.3.4* The burn sequence matrix for each room shall also specify the maximum number of evolutions that can be safely conducted during a given training period before the room is allowed to cool.

7.3.5 The fuel loads per evolution and the maximum number of sequential evolutions in each burn room shall not be exceeded under any circumstances.

Chapter 8 Exterior Live Fire Training Props

8.1 Props, Structures, and Facilities.

8.1.1 This section pertains to all exterior props where live fire training exercises occur.

8.1.2 Props used for outside live fire training shall be designed specifically for the evolution to be performed.

8.1.3 Exterior props shall be left in a safe condition upon completion of live fire training evolutions.

8.1.4 For outside training, care shall be taken to select areas that limit the hazards to both personal safety and the environment.

8.1.5 The training site shall be without obstructions that can interfere with fire-fighting operations.

8.1.6 Where live training fires are used outside, the ground cover shall be such that it does not contribute to the fire.

8.1.7 Debris hindering the access of fire fighters shall be removed prior to the beginning of the training exercise.

8.2 Inspection and Maintenance.

8.2.1 Exterior props shall be inspected visually for damage prior to live fire training evolutions.

8.2.1.1 Damage to exterior props shall be documented and the owner or AHJ shall be notified.

8.2.2 All safety devices and emergency shutdown switches, plus doors, shutters, vents, and other operable devices, shall be checked prior to any live fire training evolutions to ensure they operate correctly.

8.2.3 The structural integrity of the props shall be evaluated and documented annually.

Chapter 9 Reports and Records

9.1 General.

9.1.1* The following records and reports shall be maintained on all live fire training evolutions in accordance with the requirements of this standard:

- (1) An accounting of the activities conducted
- (2) A listing of instructors present and their assignments
- (3) A listing of all other participants
- (4) Documentation of unusual conditions encountered
- (5) Any injuries incurred and treatment rendered
- (6) Any changes or deterioration of the structure
- (7) Documentation of the condition of the premises and adjacent area at the conclusion of the training exercise

9.1.2* For acquired structures, records pertaining to the structure shall be completed.

9.1.3 Upon completion of the training session, an acquired structure shall be formally turned over to the control of the property owner.

9.1.3.1 The turnover process shall include the completion of a standard form indicating the transfer of authority for the acquired structure.

9.1.4 A post-training critique session, complete with documentation, shall be conducted to evaluate student performance and to reinforce the training that was covered.

Annex A Explanatory Material

Annex A is not a part of the requirements of this NFPA document but is included for informational purposes only. This annex contains explanatory material, numbered to correspond with the applicable text paragraphs.

A.1.1 Live fire training of entry level and experienced fire suppression personnel are high-risk activities. This risk can be effectively managed through compliance with this standard.

A.1.2 Drills conducted to familiarize fire fighters with the proper use of self-contained breathing apparatus (SCBA) in a smoke environment should not be conducted under live fire conditions.

A.1.3.3 While this standard does not deal with the suppression of fires set to train individuals on fire cause and origin, this standard does contain procedures that can be adapted to ensure maximum safety during those types of operations. For fire scenarios set with flammable or combustible liquids, fire suppression should be achieved by fixed-fire suppression systems or by exterior application of hose streams. Interior fire suppression operations in scenarios that do not involve the use of flammable or combustible liquids should be conducted in compliance with the requirements of this standard.

A.3.2.1 Authority Having Jurisdiction (AHJ). The phrase "authority having jurisdiction," or its acronym AHJ, is used in NFPA documents in a broad manner, since jurisdictions and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state, local, or other regional department or individual such as a fire chief; fire marshal; chief of a fire prevention bureau, labor department, or health department; building official; electrical inspector; or others having statutory authority. For insurance purposes, an insurance inspection department, rating bureau, or other insurance company representative may be the authority having jurisdiction. In many circumstances, the property owner or his or her designated agent assumes the role of the authority having jurisdiction; at government installations, the commanding officer or departmental official may be the authority having jurisdiction.

A.3.3.2.4.2 Live Fire Training Structure. Live fire training structures include structures built of conventional building materials, such as concrete, masonry, and steel, as well as structures built of containers, in which live fire training evolutions are conducted. This includes fixed structures that are marketed as "mobile props," such as the following:

- (1) Pre-engineered metal structures that can be disassembled and transported to a new site
- (2) Containerized structures in which one or more containers are assembled, whether single story or multi-story, for purposes of interior live fire training evolutions

Live fire training structures also include fire behavior labs (also known as "flashover" containers) and mobile live fire training props.

Live fire training structures do not include structures that are used for training in the use of SCBA where only smoke conditions are created, without a live fire, and the participants are not subjected to risk of the effects of fire other than the smoke produced.

A.4.3.1 The following job performance requirements from NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, should be used as guidance related to the list of subjects in 4.3.1:

- (1) 5.2.3 Radio use
- (2) 5.3.1 SCBA
- (3) 5.3.4 Forcible entry
- (4) 5.3.2 Vehicle safety
- (5) 5.3.6 Ground ladders
- (6) 5.3.7, 5.3.8 Fire extinguishment
- (7) 5.3.9 Search and rescue
- (8) 5.3.10 Structural fire fighting
- (9) 5.3.11 Horizontal ventilation
- (10) 5.3.12 Vertical ventilation
- (11) 5.3.13 Overhaul
- (12) 5.3.15 Water supply
- (13) 5.3.16 Fire extinguishers
- (14) 5.3.17 Scene illumination
- (15) 5.5.3 Tool maintenance
- (16) 5.5.4 Fire hose care and maintenance

Industrial fire brigade members should meet the requirements of NFPA 1081, *Standard for Industrial Fire Brigade Member Professional Qualifications*.

A.4.3.2 The type of written documentation required can vary, depending upon the instructor's familiarity with the student participants' level of training from outside agencies. All student participants from outside agencies should be allowed to participate only as official representatives of an established organization. Prior documentation should be required in order to facilitate planning of the training session.

A.4.4.2 NFPA 1403 must be applied with the understanding that every training structure, whether an acquired structure or a training center burn building, is unique. The following are just some of the factors that would affect how NFPA 1403 is applied to a specific structure:

- (1) Number of stories.
- (2) Construction (concrete, concrete block, metal building).
- (3) Type and quantity of structural protective lining system (SPLS).
- (4) Type of temperature monitoring system (TMS), if any.
- (5) Size of burn rooms.
- (6) Number of burn rooms.
- (7) Type, size, and number of windows/doors.
- (8) Type, size, and number of passive ventilation openings/chop outs.
- (9) Fuel utilized in live fire evolutions (straw, excelsior, pallets, propane gas, natural gas, or a combination).
- (10) Type of interior finish materials on the ceiling, walls, and floors. If combustible, they need to be accounted for in the fuel load evaluation, or they need to be removed. Combustible materials on the ceiling, wall, or floor surfaces can lead to a rapid transition to flashover.
- (11) Type and number of means of egress and means of escape
- (12) Prevailing winds
- (13) Altitude

A.4.4.8 The additional safety personnel can be necessary to watch for signs of fire in voids, concealed spaces, and exit paths, or combinations thereof, at acquired structures. Where fire is discovered in any of these areas, the operation should cease as a training exercise and should be treated as a working structure fire.

A.4.5 Severe weather could require the participants to respond to other incidents, or could expose trainees to danger if training takes place during severe weather. Wind velocity can contribute to spreading the fire within the training structure

or throughout a neighborhood, or wind direction could cause smoke problems in the neighborhood. Severe weather presents the potential for health and safety hazards to all persons attending and participating in an exercise. Extreme heat can cause heat exhaustion or heat stroke, and extreme cold can cause frostbite, hypothermia, or slippery surfaces. An impending severe storm can bring lightning or high winds. Such situations warrant the careful consideration of limiting activity, waiting for a storm to pass, or postponing the exercise.

A.4.6.5.1 Assignment rotation, rest, and rehabilitation of instructors shall be provided. Instructors should be provided rest and rehabilitation as required in 4.6.5.1. Instructors should remove their personal protective clothing to reduce thermal saturation of the PPE.

A.4.7.1.2 The purpose and principal function is to observe the ignition officer while igniting or maintaining the fire. Members of the fire control team should rotate duties to prevent overheating and thermal saturation.

A.4.8.2 Guidance is provided in NFPA 1851, *Standard on Selection, Care, and Maintenance of Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*, and NFPA 1852, *Standard on Selection, Care, and Maintenance of Open-Circuit Self-Contained Breathing Apparatus (SCBA)*, to assist the instructor and department in determining if personal protective clothing and breathing apparatus are in serviceable condition.

A.4.8.5 Clothing worn under personal protective clothing can degrade and cause injury to the wearer, even without damaging the protective clothing. All wearers of personal protective clothing should be aware of the dangers of clothing made from certain all-synthetic materials that can melt and then adhere to and burn the wearer even if protective clothing that meets NFPA standards is worn. Any clothing, such as shirts, pants, underwear, and sweatshirts, worn under personal protective clothing should meet the requirements of NFPA 1975, *Standard on Station/Work Uniforms for Emergency Services*, whenever possible, or clothing should be selected, at a minimum, for the fabric's ability to resist ignition. Fire-retardant fabrics and all-natural fibers should be considered.

A.4.8.7 No person should be allowed to breathe smoke, toxic vapors or fumes, products of combustion, or other contaminated atmospheres or be exposed to an oxygen-deficient atmosphere.

A.4.9.2 Participants involved in the live fire training evolutions should be instructed to report to a predetermined location for a roll call if evacuation of the acquired structure is signaled. Instructors should immediately report any personnel not accounted for to the instructor-in-charge. Examples of an evacuation signal that could be used include a whistle, apparatus air horn, or high-low electronic siren.

A.4.11 A minimum flow rate of 95 gpm (360 L/min) is necessary in order to provide adequate quantities of water to cover the planned evolution, plus a reserve for unanticipated emergencies. The appropriate quantity and exact flow rates that are needed for fire control and extinguishment should be calculated in advance, and certain factors such as equipment, manpower, fire area, and topography should be taken into consideration. Knowledge of the hose line sizes, types of nozzles, type of fire stream to be utilized, and principles of fire attack and deployment aid in determining the exact flow rates that are necessary.

A.4.11.6 Reliability should be considered when determining what constitutes valid separate sources. The intent of this paragraph is to prevent the simultaneous loss of both attack lines

and backup lines in the event of a pump or water supply failure. Where a public water supply system is used, two pumpers on two different hydrants should be used. Two pumpers drafting from the same pond or river also are appropriate, provided the source contains sufficient usable water. Where tankers or folding tanks, or both, are used, two separate pumpers should be used to supply the attack and backup lines.

A.4.11.6.1 See A.4.11.6.

A.4.12.1 Acceptable fuels include pine excelsior, wooden pallets, straw, hay, and other wood-based products.

A.4.12.6 An excessive fuel load can contribute to conditions that create unusually dangerous fire behavior. This can jeopardize structural stability, egress, and the safety of participants.

Excess fuel load can result in a ventilation-controlled fire, which can result in flameover (rollover) or flashover. These fire conditions increase the amount of thermal energy (the heat release rate of the fire) that is being transferred by conduction, convection, and radiation to any fire fighters in the compartment, which can lead to the degradation of protective equipment and injury or death. Venting a ventilation-controlled fire can result in an increase in heat release rate in the fire structure.

A.4.12.8 The instructor-in-charge is concerned with the safety of participants and the assessment of conditions that can lead to rapid, uncontrolled burning, commonly referred to as *flashover*. Flashover can trap, injure, and kill fire fighters. Conditions known to be variables affecting the attainment of flashover are as follows:

- (1) The heat release characteristics of materials used as primary fuels
- (2) The preheating of combustibles
- (3) The combustibility of wall and ceiling materials
- (4) The room geometry (e.g., ceiling height, openings to rooms)

In addition, the arrangement of the initial materials to be ignited, particularly the proximity to walls and ceilings, and the ventilation openings are important factors to be considered when assessing the potential fire growth.

A.4.12.9 Plotting the expected avenues of firespread and the time factors for expected buildup of the fire provides an extra degree of safety for the participants of the exercise. Voids can result in sudden and unexpected vertical spread of the fire and trap participants by cutting off exit routes, or can result in unexpected weakening of the structural members, leading to collapse. To compensate for this potential hazard, the instructor-in-charge should prescribe primary and secondary exit paths for participants in the exercises.

A.4.12.10 Incidents of injuries and deaths during live fire training exercises indicate that fire growth dynamics were not considered or were inaccurately assessed prior to the beginning of the exercises. Fire growth is typically linear until the flame height reaches the ceiling; thereafter, rapid acceleration can be expected. It might be necessary to remove combustible wall and ceiling materials, reduce the amount of furnishings, or take other similar measures to reduce rapid fire growth. Careful consideration should be given to the presence of combustible void spaces, and steps should be taken to ensure that the fire is not able to gain unexpected growth in such areas.

A.4.12.11 Propane and liquefied natural gas remain in the liquid state only when they are stored and distributed under pressure. When either of these gases is released, the difference in the storage and atmospheric pressures can cause the liquid to convert quickly to a gas. During this conversion, liquid propane, for example, can expand to 270 times

its volume. With such a high expansion rate, a leaking liquid propane pipe has the potential to cause the space to reach an explosive level.

A.4.12.11.2 The safety person at the remote shutoff should have the authority to shut off the fuel supply to the prop when, in the safety person's judgment, the prop has malfunctioned, the fire has gone dangerously out of control, or the extinguishment team is in jeopardy.

A.4.12.11.7 The list of the items to be removed prior to a vehicle burn evolution should consist of, but should not be limited to, bumper compression cylinders, shock absorbers, fuel tanks, drive shafts, batteries, air bags and igniters, and brake shoes (asbestos). The oil pan, transmission, and differential drain plugs should be removed, and the fluids should be drained and disposed of properly.

A.4.15.9.1 Such safeguards can include street closings, traffic rerouting, signs, and police traffic control.

A.5.1.1 Where live fire training structures are available, they should be used instead of acquired structures.

A.5.1.3 The permits required for the exercise could include the following:

- (1) Air quality
- (2) Water runoff
- (3) Water usage
- (4) Burning
- (5) Traffic

Other permits could be required and thorough research of required permits should be completed prior to acceptance of the building for use for training.

A.5.1.4 Information pertaining to building ownership should be reviewed by the legal counsel of the AHJ prior to acceptance of the structure.

A.5.1.6 Information regarding the written permission of the building owner should be reviewed by the legal counsel of the AHJ prior to acceptance of the structure.

A.5.1.8 Information regarding cancellation of insurance by the building owner should be reviewed by the legal counsel of the AHJ prior to acceptance of the structure.

A.5.2.2 Care should be exercised in the neutralization of hazards posed by closed tanks and vessels. The vessel or its contents can pose a hazard that should be eliminated. Appropriate references should be consulted or assistance should be obtained based on the specific circumstances encountered. The area within the tank should be filled with dry sand as a preferred means of rendering the internal atmosphere inert. Under no circumstances should water or other liquids be utilized as a means of inerting a tank or other closed vessel.

A.5.2.4.5 Roof ventilation openings can consist of precut panels or hinged covers.

A.5.2.4.6 Low-density combustible fiberboard has been implicated as a major factor in the following rapidly spreading fires that resulted in fatalities:

- (1) Our Lady of the Angels School (Chicago, IL, 1958)
- (2) Hartford Hospital (Hartford, CT, 1961)
- (3) Opemiska Social Club (Chapais, Quebec, 1980)
- (4) Boulder Fire Department training fire (Boulder, CO, 1982)

Unconventional interior finishes include burlap, carpeting, and artificial turf.

A.5.2.4.7 The collapse of overhead structural members can result from the combined effect of the weight of both live and dead overhead loads as well as the loss of structural integrity caused by fire. Linoleum is a potential fuel source, particularly after being preheated by repeated fire exposure, and thus can contribute to an unanticipated increase in fire intensity.

A.5.2.5 Figure A.5.2.5 provides a sample form for the inspection of acquired structure and to identify hazards.

A.6.2.1 There should be ongoing concern for the progressive damage to live fire training structures associated with fire intensity during live fire training evolutions. Excessive fire intensity can result in accelerated destruction of the live fire training structure and can increase the risk to personnel to an unacceptable level.

Examples of common damage to check for include the following:

- (1) Visible structural defects such as cracks, spalls, or warps in structural floors, columns, beams, and walls.
- (2) Thermal linings. Thermal linings are intended to protect the structural components. Exposure to live fire training can cause the thermal linings to wear out over time. Portions of it can loosen and fall out, anchoring devices can loosen, and reinforcing and supporting pieces can corrode, creating a safety concern for occupants. In addition, cracks, holes, openings, gaps, or penetrations in the thermal lining can lead to damage to the structure behind the lining.
- (3) Doors. Doors in live fire training structures at times do not operate properly, sticking shut during training and creating safety problems relating to emergency egress.
- (4) Hinges. A rusted hinge at a second-floor window shutter could cause the shutter to fall to the ground below.
- (5) Loose, rusted, or damaged handrails and guardrails.
- (6) Loose or missing stair nosings, or damage to stair treads.

A.6.2.1.1 Figure A.6.2.1.1 is an example of a live fire training facility inspection form.

A.6.2.6 Personnel making the annual structural integrity evaluation should understand the structural system that is being evaluated and where damage is most likely to occur, given the unique design of that live fire training structure. For example, live fire training structures constructed of hollow core plank roofs and floors supported on masonry bearing walls tend to exhibit several problems, such as the following, listed below, which would be helpful to know when conducting the evaluation:

- (1) Cracks occur in the topping slabs directly over the joints between the planks, causing leaks into the structure and onto thermal linings below.
- (2) Cracks occur in the ends of the planks and at the two courses of masonry block below the plank bearing points.
- (3) Vertical cracks occur in masonry bearing walls at building corners.
- (4) Cracks in the bottoms of the planks occur below the hollow cells and at the bottom corners of the planks.
- (5) Topping slabs separate from the tops of the planks, reducing the structural capacity of the structural system.
- (6) Cracks in the topping slabs near guardrail anchor points could cause guardrails to loosen.

SITE INSPECTION WORKSHEET — RESIDENTIAL PROPERTIES

Instructors' Names: _____

Date: _____

Site Address: _____

Construction Date: _____

Parcel # / PIN: _____

Comments: _____

Category	Items	Description/Location/Notes	Quantity
Universal Wastes	Fluorescent/HID Fixtures	_____	_____
	Batteries	_____	_____
	Mercury Devices	_____	_____
Building Materials	Exterior Siding	_____	_____
	Roofing	_____	_____
	Paint Condition	_____	_____
	Mold Condition	_____	_____
	Septic System	_____	_____
	Wells	_____	_____
	Treated Wood	_____	_____
Refrigerants	Air Conditioner	_____	_____
	Refrigerator/Ice Box	_____	_____
	Other	_____	_____
Household Wastes	Waste Oil	_____	_____
	Fuel	_____	_____
	Paints/Solvents	_____	_____
	Household Cleaners	_____	_____
	Yard Care Products	_____	_____
	Other	_____	_____
Building Structures	Basement/Crawl Space	_____	_____
	Garage	_____	_____
	Shed	_____	_____
	Other	_____	_____

Other Potential Issues:

FIGURE A.5.2.5 Example of a Site Inspection Worksheet.

LIVE STRUCTURAL FIRE TRAINING FACILITY INSPECTION

Region: _____
Facility: _____
Date: _____
Inspected by: _____

Legend: ✓ = OK N = Noteworthy D = Requires Attention

GENERAL

- 1) _____ Floors, walls, stairs, and other structural components appear capable of withstanding the weight of the contents, participants, and accumulated water.

EXTERIOR

- 2) _____ Perimeter lighting
- 3) _____ General appearance
- 4) _____ Exterior of structure
- 5) _____ Windows
- 6) _____ Doors
- 7) _____ Railings
- 8) _____ Stairs

INTERIOR

- 9) _____ Housekeeping (swept clean, no fuel storage on fire floor)
- 10) _____ Windows/shutters
- 11) _____ Functional doors
- 12) _____ Lined ceilings/walls (crazing, cracking, delamination, metal mesh visible)
- 13) _____ High temperature linings (loose/damaged tile, exposed bolts)
- 14) _____ Burn racks
- 15) _____ Fuel inventory/storage

OTHER

- 16) _____
- 17) _____

Documentation of Issues:

Item #	Description

Note: If damage is present in approved burn rooms, utilize the form on the reverse side to specify the details of the damage.

FIGURE A.6.2.1.1 Example of a Live Structural Fire Training Facility Inspection Form.

LIVE STRUCTURAL FIRE TRAINING FACILITY INSPECTION (continued)

Describe in detail of any damage below and attach photos.

Floor: _____ Room: _____

Wall or ceiling: _____ Area involved (ft or in.): _____

Damage description: _____

Distance in Feet of the Entire Burn Room																				
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1																				
2																				
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				
11																				
12																				
13																				
14																				
15																				
16																				
17																				
18																				
19																				
20																				

Indicate the entire size of the burn room and the exact area that is damaged.

FIGURE A.6.2.1.1 Continued

Ideally, the architect/engineer that designed the live fire training structure would have provided a description of what to look for during the periodic evaluations. If no such description was obtained when the live fire training structure was first built, then the AHJ should retain a licensed professional engineer with live fire training structure experience and expertise or other competent professional as determined by the building owner or AHJ to help create such a description.

A.6.2.7 Routine maintenance is important to providing a safe, durable live fire training structure for live fire training. Periodic engineering evaluations are one step in that process. Live fire training structures present unique engineering problems that are not taught to engineers in college or in their daily practice of engineering office buildings, schools, and fire stations. Before a registered (licensed) Professional Engineer (P.E.) understands live fire training structure engineering, it takes significant efforts on the part of the P.E. to learn how live fire training structures are used, how repetitive live fire training affects structural and non-structural elements within the live fire training structure, and what materials have been proven to work (or not work) within such a harsh environment. This effort typically requires research and educational efforts and experience with live fire training structure projects.

Because the required evaluation is for structural integrity, the P.E. performing the evaluation should be a structural engineer or teamed with a structural engineer to perform the evaluation. Many states do not license P.E.s by discipline; "P.E." could refer to a structural engineer or to some other engineering discipline, such as electrical, mechanical, fire protection, or aeronautical. State laws require P.E.s to offer engineering services for only those branches of engineering for which they are qualified. Therefore, a P.E. who is an electrical engineer or fire protection engineer with no structural qualifications would not be allowed, under law, to evaluate the structural integrity of a live fire training structure.

Note that a P.E. with refractive materials experience and expertise, but not live fire training structure experience and expertise, might not have sufficient understanding of how refractory concrete performs in a live fire training structure environment. Many P.E.s with refractive materials experience have gained that experience working with industrial applications in which furnaces are heated and cooled slowly. Certain applications of refractory concrete work well under those furnace conditions. However, the same applications of refractory concrete at times work poorly in the live fire training structure environment, where rapid heating, rapid cooling, and thermal shock deteriorate refractory concrete differently than a furnace application would. Many P.E.s with only refractive materials experience, but no live fire training structure experience, do not know this. As a result, the requirement for live fire training structure experience and expertise has been added to the standard. In many cases, the P.E. retained to evaluate the integrity can also, under the same contract, be required to make recommendations for how to repair, maintain, or improve the live fire training structure.

The phrase "with live fire training structure experience and expertise" must be interpreted by each entity following its own local and state laws and guidelines. The intent is for the P.E. to have performed at least one live fire training structure project previously, so that the entity hiring the P.E. will benefit from the educational and research efforts performed, and ex-

perience gained, by the P.E. for the previous live fire training structure project(s). This experience could include a previous live fire training structure evaluation, the repair or renovation to an existing live fire training structure, or the design of a new live fire training structure. In many cases, it would be acceptable for a P.E. without live fire training structure experience or expertise to perform the evaluation as long as he or she has teamed with a P.E. with live fire training structure experience or expertise.

A.6.2.8 Refractory concrete should not be used as a structural element. Structural calcium aluminate refractory concrete has been found to delaminate (crack and lose bond) along the lines of reinforcing within walls and suspended slabs, presenting serious structural deficiencies that threaten the life and safety of training personnel.

A.6.2.9 Heat can soak through thermal linings and reach the protected structure, especially if the linings are cracked or otherwise require maintenance when live fire training occurs. This heat could damage the structure, a hidden condition that would otherwise go undetected if the panels are not occasionally removed to expose the hidden conditions.

A.7.2.1 See A.6.2.1.

A.7.2.1.1 See A.6.2.1.1.

A.7.2.5 See A.6.2.6.

A.7.2.6 See A.6.2.7.

A.7.2.7 See A.6.2.8.

A.7.2.8 See A.6.2.9.

A.7.3.3 Reducing fuel loads for successive evolutions to maintain a safe environment should be considered.

A.7.3.4 The following facts will affect conditions encountered in a burn room during a live fire evolution:

- (1) Larger burn rooms and rooms with higher ceilings will have more cubic feet of air than smaller burn rooms.
- (2) Generally, with a given quantity of fuel, the lower the cubic footage in a room, the higher the temperatures and more rigorous the environment will be.
- (3) As the number of openings in a burn room increase, the available ventilation area increases, resulting in typically lower temperatures and less severe environments.
- (4) The construction of the burn room will affect how much energy the room will retain with each successive evolution. All burn rooms will retain a level of heat with each burn. The temperature and radiant heat in the burn room will increase with each additional evolution. At some point, every room will become too hot to safely conduct further training. Outside environmental conditions might also affect this.

A.9.1.1 See NFPA 1401, *Recommended Practice for Fire Service Training Reports and Records*, for additional guidance on training records.

A.9.1.2 Figure A.9.1.2(a) shows a standard notice of cancellation or nonrenewal of insurance. Figure A.9.1.2(b) shows a sample release form that can be used with acquired structures. The exact form should be approved by local officials.



NOTICE OF CANCELLATION OR NONRENEWAL

of _____

KIND OF POLICY

POLICY NO.	ISSUED THROUGH AGENCY OR OFFICE AT:	CANCELLATION OR TERMINATION WILL TAKE EFFECT AT: (DATE) (HOUR-STANDARD TIME)	DATE OF NOTICE

INSURANCE COMPANY:

NAME AND ADDRESS OF INSURED:

(Applicable item is marked **X**)

CANCELLATION	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that your insurance will cease at and from the hour and date mentioned above. If the premium has been paid, premium adjustment will be made as soon as practicable after cancellation becomes effective. If the premium has not been paid, a bill for the premium earned to the time of cancellation will be forwarded in due course.
	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that your insurance will cease at and from the hour and date mentioned above due to nonpayment of premium. A bill for the premium earned to the time of cancellation will be forwarded in due course.
NONRENEWAL	<input type="checkbox"/> You are hereby notified in accordance with the terms and conditions of the above-mentioned policy that the above-mentioned policy will expire effective at and from the hour and date mentioned above and the policy will NOT be renewed.

IMPORTANT NOTICE In compliance with the Fair Credit Reporting Act (Public Law 91-508), you are hereby informed that the action taken above is being taken wholly or partly because of information contained in a consumer report from the following consumer reporting agency:

NAME

ADDRESS

GU 8811b (Ed. 3-73) Uniform Printing & Supply Div.

INSURED'S COPY

Authorized Representative

FIGURE A.9.1.2(a) Standard Notice of Cancellation or Nonrenewal of Insurance Form.

Release Form

_____ Fire Department

Address _____

City _____ State _____

Date _____

Having agreed with the Building Official, City of _____

_____ that a structure owned by me and located at _____

_____ is unfit for human habitation and is beyond rehabilitation, I further agree that the structure should be demolished. In order that demolition may be accomplished, I give my consent to the

City of _____

to demolish, by burning or other means, the said structure.

I further release the City of _____

_____ from any claim for loss resulting from such demolition.

Owner/Agent

Owner/Agent

Witness

FIGURE A.9.1.2(b) Sample Release Form.

Annex B Live Fire Evolution Sample Checklist

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

B.1 Sample Checklist. Figure B.1 provides a checklist for a live fire evolution.

Annex C Responsibilities of Personnel

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

C.1 Responsibilities. The lists in Figure C.1 outline the responsibilities of participants in a live fire training evolution.

Annex D Heat Exhaustion and Heat Stroke in Training

This annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

D.1 Heat-Related Illnesses. The two most serious heat-related illnesses are heat exhaustion and heat stroke. The following material is excerpted from the NIOSH document *Occupational Exposure to Hot Environments, Revised Criteria*.

Symptoms of heat exhaustion include fatigue, nausea, headache, dizziness, pallor, weakness, and thirst. Factors that predispose a person to heat exhaustion include sustained exertion in the heat, failure to replace the water lost in sweat, and lack of acclimatization. Heat exhaustion responds readily to prompt treatments such as moving to a cooler environment, resting in a recumbent position, and taking fluids by mouth.

Heat stroke is the more serious of the heat-related illnesses and is considered a medical emergency. Symptoms of heat stroke include hot, red, dry skin, a rectal temperature of 104°F (40°C) or above, confusion, possible convulsions or loss of consciousness, or any combination of these symptoms. Factors that predispose a person to heat stroke include sustained exertion in the heat by unacclimatized workers, lack of physical fitness, obesity, recent alcohol intake, dehydration, individual susceptibility, and chronic cardiovascular disease. Heat stroke should be treated immediately. Treatments to reduce body temperature rapidly include immersing in chilled water, rinsing with alcohol, wrapping in a wet sheet, or fanning with cool, dry air, or any combination of these treatments. A physician's care is necessary to treat possible secondary disorders such as shock or kidney failure. While heat exhaustion cases greatly outnumber heat stroke cases, every case of heat exhaustion should be treated as having the potential to develop into heat stroke.

Acclimatization is a physiological adaptation to heat stress that occurs over a short period of time. After acclimatization has occurred, the body sweats more while losing less salt and can maintain a lower core temperature and lower cardiovascular demands. A person becomes acclimatized to a certain work intensity and temperature with repeated exposures to that work load and temperature. Formal acclimatization procedures might not be necessary for all fire fighters; however, training drills should be held outdoors regularly so that seasonal acclimatization can occur. For additional protection against heat stress, fire fighters might want to perform their regular aerobic training activities outdoors, especially during the spring and summer.

The metabolic demands of fire fighting range from 60 percent to 100 percent of maximum aerobic capacity. Tasks such as stair climbing, roof venting, and rescue operations, when performed in full gear, have an energy cost of 85 percent to 100 percent of maximum capacity and lead to near maximum heart rates.

It is clear from these estimates that a high level of cardiovascular fitness is an advantage in performing fire-fighting tasks. The higher level of fitness allows a longer work period and provides a greater reserve in case of an unexpected increase in work demands or in extreme environmental conditions.

There are fire incidents during which even the fittest, most acclimatized fire fighter is exposed to significant heat stress. For this reason, many fire departments have adopted formal

LIVE FIRE EVOLUTION SAMPLE CHECKLIST

PERMITS, DOCUMENTS, NOTIFICATIONS, INSURANCE.

- ___ 1. Written documentation received from owner:
 - Permission to burn structure
 - Proof of clear title
 - Certificate of insurance cancellation
 - Acknowledgment of post-burn property condition
- ___ 2. Local burn permit received
- ___ 3. Permission obtained to utilize fire hydrants
- ___ 4. Notification made to appropriate dispatch office of date, time, and location of burn
- ___ 5. Notification made to all affected police agencies:
 - Received authority to block off roads
 - Received assistance in traffic control
- ___ 6. Notification made to owners and users of adjacent property of date, time, and location of burn
- ___ 7. Liability insurance obtained covering damage to other property
- ___ 8. Written evidence of prerequisite training obtained from participating students from outside agencies

PREBURN PLANNING.

- ___ 1. Preburn plans made, showing the following:
 - Site plan drawing, including all exposures
 - Floor plan detailing all rooms, hallways, and exterior openings
 - Location of command post
 - Position of all apparatus
 - Position of all hoses, including backup lines
 - Location of emergency escape routes
 - Location of emergency evacuation assembly area
 - Location of ingress and egress routes for emergency vehicles
- ___ 2. Available water supply determined
- ___ 3. Required fire flow determined for the acquired structure/live fire training structure/burn prop and exposure buildings
- ___ 4. Required reserve flow determined (50 percent of fire flow)
- ___ 5. Apparatus pumps obtained that meet or exceed the required fire flow for the building and exposures
- ___ 6. Separate water sources established for attack and backup hose lines

- ___ 7. Periodic weather reports obtained
- ___ 8. Parking areas designated and marked:
 - Apparatus staging
 - Ambulances
 - Police vehicles
 - Press vehicles
 - Private vehicles
- ___ 9. Operations area established and perimeter marked
- ___ 10. Communications frequencies established, equipment obtained

TRAINING STRUCTURE PREPARATION.

- ___ 1. Training structure inspected to determine structural integrity
- ___ 2. All utilities disconnected (acquired structures only)
- ___ 3. Highly combustible interior wall and ceiling coverings removed
- ___ 4. All holes in walls and ceilings patched
- ___ 5. Materials of exceptional weight removed from above training area (or area sealed from activity)
- ___ 6. Ventilation openings of adequate size precut for each separate roof area
- ___ 7. Windows checked and operated, openings closed
- ___ 8. Doors checked and operated, opened or closed, as needed
- ___ 9. Training structure components checked and operated:
 - Roof scuttles
 - Automatic ventilators
 - Mechanical equipment
 - Lighting equipment
 - Manual or automatic sprinklers
 - Standpipes
- ___ 10. Stairways made safe with railings in place
- ___ 11. Chimney checked for stability
- ___ 12. Fuel tanks and closed vessels removed or adequately vented
- ___ 13. Unnecessary inside and outside debris removed
- ___ 14. Porches and outside steps made safe
- ___ 15. Cisterns, wells, cesspools, and other ground openings fenced or filled

FIGURE B.1 Sample Checklist for Procedures for a Live Fire Evolution.

LIVE FIRE EVOLUTION SAMPLE CHECKLIST *(continued)*

- ___ 16. Hazards from toxic weeds, hives, and vermin eliminated
- ___ 17. Hazardous trees, brush, and surrounding vegetation removed
- ___ 18. Exposures such as buildings, trees, and utilities removed or protected
- ___ 19. All extraordinary exterior and interior hazards remedied
- ___ 20. Fire "sets" prepared:
 - Class A materials only
 - No flammable or combustible liquids
 - No contaminated materials

PREBURN PROCEDURES.

- ___ 1. All participants briefed:
 - Training structure layout
 - Crew and instructor assignments
 - Safety rules
 - Training structure evacuation procedure
 - Evacuation signal (demonstrate)
- ___ 2. All hose lines checked:
 - Sufficient size for the area of fire involvement
 - Charged and test flowed
 - Supervised by qualified instructors
 - Adequate number of personnel
- ___ 3. Necessary tools and equipment positioned

- ___ 4. Participants checked:
 - Approved full protective clothing
 - Self-contained breathing apparatus (SCBA)
 - Adequate SCBA air volume
 - All equipment properly donned

POSTBURN PROCEDURES.

- ___ 1. All personnel accounted for
- ___ 2. Remaining fires overhauled, as needed
- ___ 3. Training structure inspected for stability and hazards where more training is to follow (*see Training Structure Preparation*)
- ___ 4. Training critique conducted
- ___ 5. Records and reports prepared, as required:
 - Account of activities conducted
 - List of instructors and assignments
 - List of other participants
 - Documentation of unusual conditions or events
 - Documentation of injuries incurred and treatment rendered
 - Documentation of changes or deterioration of live fire training structure
 - Acquired structure release
 - Student training records
 - Certificates of completion
- ___ 6. Building and property released to owner, release document signed

RELEASE FORM

Having agreed with the Building Official, City of _____, that a structure owned by me and located at _____ is unfit for human habitation and is beyond rehabilitation, I further agree that the structure should be demolished. In order that demolition may be accomplished, I give my consent to the City of _____ to demolish, by burning or other means, the said structure.

I further release the City of _____ from any claim for loss resulting from such demolition.

Fire Department _____
Address _____
City, State _____
Date _____
Owner/Agent _____
Owner/Agent _____
Witness _____

FIGURE B.1 *Continued*

RESPONSIBILITIES OF PERSONNEL

INSTRUCTOR-IN-CHARGE

- 1. Plan and coordinate all training activities
- 2. Monitor activities to ensure safe practices
- 3. Inspect training structure integrity prior to each fire
- 4. Assign instructors:
 - Attack hose lines
 - Backup hose lines
 - Functional assignments
 - Teaching assignments
- 5. Brief instructors on responsibilities:
 - Accounting for assigned students
 - Assessing student performance
 - Clothing and equipment inspection
 - Monitoring safety
 - Achieving tactical and training objectives
- 6. Assign coordinating personnel, as needed:
 - Emergency Medical Services
 - Communications
 - Water supply
 - Apparatus staging
 - Equipment staging
 - Breathing apparatus
 - Personnel welfare
 - Public relations
- 7. Ensure adherence to this standard by all persons within the training area

INSTRUCTOR

- 1. Monitor and supervise assigned students (no more than five per instructor)
- 2. Inspect students' protective clothing and equipment
- 3. Account for assigned students, both before and after evolutions

SAFETY OFFICER

- 1. Prevent unsafe acts
- 2. Eliminate unsafe conditions
- 3. Intervene and terminate unsafe acts
- 4. Supervise additional safety personnel, as needed
- 5. Coordinate lighting of fires with instructor-in-charge
- 6. Ensure compliance of participants' personal equipment with applicable standards:
 - Protective clothing
 - Self-contained breathing apparatus (SCBA)
 - Personal alarm devices, where used
- 7. Ensure that all participants are accounted for, both before and after each evolution

STUDENT

- 1. Acquire prerequisite training
- 2. Become familiar with building layout
- 3. Wear approved full protective clothing
- 4. Wear approved SCBA
- 5. Obey all instructions and safety rules
- 6. Provide documentation of prerequisite training, where from an outside agency

FIGURE C.1 Checklist for Responsibilities of Personnel.

procedures for on-scene rehabilitation and have incorporated them into their manuals for standard operating procedures. The general goals of rehabilitation are as follows:

- (1) To provide physical and mental rest, allowing the fire fighter to recuperate from demands of emergency operations and adverse environmental conditions
- (2) To revitalize fire fighters by providing fluid replacement and food as needed
- (3) To provide medical monitoring, including treatment of injuries, to determine if and when fire fighters are able to return to action

Annex E Informational References

E.1 Referenced Publications. The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not part of the requirements of this document unless also listed in Chapter 2 for other reasons.

E.1.1 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 1001, *Standard for Fire Fighter Professional Qualifications*, 2008 edition.

NFPA 1081, *Standard for Industrial Fire Brigade Member Professional Qualifications*, 2012 edition.

NFPA 1401, *Recommended Practice for Fire Service Training Reports and Records*, 2012 edition.

NFPA 1851, *Standard on Selection, Care, and Maintenance of Protective Ensembles for Structural Fire Fighting and Proximity Fire Fighting*, 2008 edition.

NFPA 1852, *Standard on Selection, Care, and Maintenance of Open-Circuit Self-Contained Breathing Apparatus (SCBA)*, 2008 edition.

NFPA 1975, *Standard on Station/Work Uniforms for Emergency Services*, 2009 edition.

E.1.2 Other Publications.

E.1.2.1 NIOSH Publications. National Institute for Occupational Safety and Health, Centers for Disease Control and Prevention, 1600 Clifton Road, Atlanta, GA 30333.

Occupational Exposure to Hot Environments, Revised Criteria.

E.2 Informational References. (Reserved)

E.3 References for Extracts in Informational Sections. (Reserved)



Index

Copyright © 2012 National Fire Protection Association. All Rights Reserved.

The copyright in this index is separate and distinct from the copyright in the document that it indexes. The licensing provisions set forth for the document are not applicable to this index. This index may not be reproduced in whole or in part by any means without the express written permission of NFPA.

<p>-A-</p> <p>Acquired Prop Definition..... 3.3.1</p> <p>Acquired Structures Chap. 5 Exits 5.4 Hazards 5.2 Rapid Intervention Crew (RIC) 5.5 Structures and Facilities 5.1 Utilities..... 5.3</p> <p>Administration..... Chap. 1 Application 1.3 Purpose 1.2, A.1.2 Scope..... 1.1, A.1.1</p> <p>Authority Having Jurisdiction (AHJ) Definition 3.2.1, A.3.2.1</p> <p>-B-</p> <p>Backdraft Definition..... 3.3.2</p> <p>-C-</p> <p>Combustible Definition..... 3.3.3</p> <p>Conduction Definition..... 3.3.4</p> <p>Convection Definition..... 3.3.5</p> <p>-D-</p> <p>Definitions Chap. 3</p> <p>Deflagration Definition..... 3.3.6</p> <p>Demonstration Definition..... 3.3.7</p> <p>-E-</p> <p>Emergency Medical Services Definition..... 3.3.8</p> <p>Evolution Definition..... 3.3.9</p> <p>Explanatory Material Annex A</p> <p>Exterior Live Fire Training Props..... Chap. 8 Inspection and Maintenance 8.2 Props, Structures, and Facilities 8.1</p> <p>-F-</p> <p>Flameover (Rollover.) Definition 3.3.10</p> <p>Flashover Definition 3.3.11</p> <p>Fuel Load Definition 3.3.12</p> <p>-G-</p> <p>Gas-Fired Live Fire Training Structures Chap. 6 Inspection and Testing 6.2 Structures and Facilities 6.1</p>	<p>General Chap. 4 Application 4.1 Communication 4.9 Emergency Medical Services (EMS) 4.10 Extreme Weather 4.5, A.4.5 Fire Control Team 4.7 Fuel Materials 4.12 Instructor in Charge and Instructors 4.6 Training Instructors on How to Use Specialty Props..... 4.6.12 Parking/Staging 4.13 Permits..... 4.2 Personal Protective Clothing 4.8 Preburn Plan/Briefing 4.15 Safety Officer..... 4.4 Student Prerequisites 4.3 Visitors and Spectators 4.14 Water Supply..... 4.11, A.4.11</p> <p>-H-</p> <p>Heat Exhaustion and Heat Stroke in Training Annex D</p> <p>-I-</p> <p>Informational References Annex E</p> <p>Instructor Definition 3.3.13</p> <p>Instructor-in-Charge Definition 3.3.14</p> <p>-L-</p> <p>Live Fire Definition 3.3.15</p> <p>Live Fire Evolution Sample Checklist Annex B</p> <p>-N-</p> <p>Non-Gas-Fired Live Fire Training Structures Chap. 7 Inspection and Testing 7.2 Sequential Live Fire Burn Evolutions 7.3 Structures and Facilities 7.1</p> <p>-P-</p> <p>Participant Definition 3.3.16</p> <p>Personal Accountability Report (PAR) Definition 3.3.17</p> <p>Personal Protective Clothing Definition 3.3.18</p> <p>Personal Protective Equipment Definition 3.3.19</p> <p>Pyrolysate Definition 3.3.20</p> <p>-R-</p> <p>Radiation Definition 3.3.21</p> <p>Referenced Publications..... Chap. 2 General 2.1 NFPA Publications 2.2 Other Publications 2.3 References for Extracts in Mandatory Sections 2.4</p> <p>Reports and Records..... Chap. 9 General 9.1</p> <p>Responsibilities of Personnel Annex C</p>
--	---

-S-

Safety Officer
Definition 3.3.22

Shall
Definition 3.2.2

Should
Definition 3.2.3

Standard
Definition 3.2.4

Student
Definition 3.3.23

-T-

Training Structure
Acquired Structure
Definition 3.3.24.1
Definition 3.3.24

Live Fire Training Structure
Definition 3.3.24.2, A.3.3.24.2

-V-

Ventilation-Controlled Fire
Definition 3.3.25

Sequence of Events Leading to Issuance of an NFPA Committee Document

Step 1: Call for Proposals

- Proposed new Document or new edition of an existing Document is entered into one of two yearly revision cycles, and a Call for Proposals is published.

Step 2: Report on Proposals (ROP)

- Committee meets to act on Proposals, to develop its own Proposals, and to prepare its Report.
- Committee votes by written ballot on Proposals. If two-thirds approve, Report goes forward. Lacking two-thirds approval, Report returns to Committee.
- Report on Proposals (ROP) is published for public review and comment.

Step 3: Report on Comments (ROC)

- Committee meets to act on Public Comments to develop its own Comments, and to prepare its report.
- Committee votes by written ballot on Comments. If two-thirds approve, Report goes forward. Lacking two-thirds approval, Report returns to Committee.
- Report on Comments (ROC) is published for public review.

Step 4: Technical Report Session

- “*Notices of intent to make a motion*” are filed, are reviewed, and valid motions are certified for presentation at the Technical Report Session. (“Consent Documents” that have no certified motions bypass the Technical Report Session and proceed to the Standards Council for issuance.)
- NFPA membership meets each June at the Annual Meeting Technical Report Session and acts on Technical Committee Reports (ROP and ROC) for Documents with “certified amending motions.”
- Committee(s) vote on any amendments to Report approved at NFPA Annual Membership Meeting.

Step 5: Standards Council Issuance

- Notification of intent to file an appeal to the Standards Council on Association action must be filed within 20 days of the NFPA Annual Membership Meeting.
- Standards Council decides, based on all evidence, whether or not to issue Document or to take other action, including hearing any appeals.

Committee Membership Classifications

The following classifications apply to Technical Committee members and represent their principal interest in the activity of the committee.

- M *Manufacturer:* A representative of a maker or marketer of a product, assembly, or system, or portion thereof, that is affected by the standard.
- U *User:* A representative of an entity that is subject to the provisions of the standard or that voluntarily uses the standard.
- I/M *Installer/Maintainer:* A representative of an entity that is in the business of installing or maintaining a product, assembly, or system affected by the standard.
- L *Labor:* A labor representative or employee concerned with safety in the workplace.
- R/T *Applied Research/Testing Laboratory:* A representative of an independent testing laboratory or independent applied research organization that promulgates and/or enforces standards.
- E *Enforcing Authority:* A representative of an agency or an organization that promulgates and/or enforces standards.
- I *Insurance:* A representative of an insurance company, broker, agent, bureau, or inspection agency.
- C *Consumer:* A person who is, or represents, the ultimate purchaser of a product, system, or service affected by the standard, but who is not included in the *User* classification.
- SE *Special Expert:* A person not representing any of the previous classifications, but who has a special expertise in the scope of the standard or portion thereof.

NOTES:

1. “Standard” connotes code, standard, recommended practice, or guide.
2. A representative includes an employee.
3. While these classifications will be used by the Standards Council to achieve a balance for Technical Committees, the Standards Council may determine that new classifications of members or unique interests need representation in order to foster the best possible committee deliberations on any project. In this connection, the Standards Council may make appointments as it deems appropriate in the public interest, such as the classification of “Utilities” in the National Electrical Code Committee.
4. Representatives of subsidiaries of any group are generally considered to have the same classification as the parent organization.

NFPA Document Proposal Form

NOTE: All Proposals must be received by 5:00 pm EST/EDST on the published Proposal Closing Date.

For further information on the standards-making process, please contact the Codes and Standards Administration at 617-984-7249 or visit www.nfpa.org/codes.

For technical assistance, please call NFPA at 1-800-344-3555.

FOR OFFICE USE ONLY

Log #:

Date Rec'd:

Please indicate in which format you wish to receive your ROP/ROC electronic paper download
(Note: If choosing the download option, you must view the ROP/ROC from our website; no copy will be sent to you.)

Date April 1, 200X Name John J. Doe

Tel. No. 716-555-1234

Company Air Canada Pilot's Association

Email

Street Address 123 Summer Street Lane

City Lewiston

State NY Zip 14092

***If you wish to receive a hard copy, a street address MUST be provided. Deliveries cannot be made to PO boxes.

Please indicate organization represented (if any)

1. (a) NFPA Document Title National Fuel Gas Code

NFPA No. & Year 54, 200X Edition

(b) Section/Paragraph 3.3

2. Proposal Recommends (check one): new text revised text deleted text

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): [Note: Proposed text should be in legislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).]

Revise definition of effective ground-fault current path to read:

3.3.78 Effective Ground-Fault Current Path. An intentionally constructed, permanent, low impedance electrically conductive path designed and intended to carry underground electric fault current ~~conditions~~ from the point of a ground fault on a wiring system to the electrical supply source.

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that would be resolved by your recommendation; give the specific reason for your Proposal, including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

Change uses proper electrical terms.

5. Copyright Assignment

(a) I am the author of the text or other material (such as illustrations, graphs) proposed in the Proposal.

(b) Some or all of the text or other material proposed in this Proposal was not authored by me. Its source is as follows: (please identify which material and provide complete information on its source)

ABC Co.

I hereby grant and assign to the NFPA all and full rights in copyright in this Proposal and understand that I acquire no rights in any publication of NFPA in which this Proposal in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this Proposal and that I have full power and authority to enter into this assignment.

Signature (Required)

John J. Doe

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

Mail to: Secretary, Standards Council - National Fire Protection Association
1 Batterymarch Park - Quincy, MA 02169-7471 OR

Fax to: (617) 770-3500 OR Email to: proposals_comments@nfpa.org

NFPA Document Proposal Form

NOTE: All Proposals must be received by 5:00 pm EST/EDST on the published Proposal Closing Date.

For further information on the standards-making process, please contact the Codes and Standards Administration at 617-984-7249 or visit www.nfpa.org/codes.

For technical assistance, please call NFPA at 1-800-344-3555.

FOR OFFICE USE ONLY

Log #:

Date Rec'd:

Please indicate in which format you wish to receive your ROP/ROC electronic paper download
(Note: If choosing the download option, you must view the ROP/ROC from our website; no copy will be sent to you.)

Date _____ Name _____ Tel. No. _____
Company _____ Email _____
Street Address _____ City _____ State _____ Zip _____

*****If you wish to receive a hard copy, a street address MUST be provided. Deliveries cannot be made to PO boxes.**

Please indicate organization represented (if any)

1. (a) NFPA Document Title _____ NFPA No. & Year _____
(b) Section/Paragraph _____

2. Proposal Recommends (check one): new text revised text deleted text

3. Proposal (include proposed new or revised wording, or identification of wording to be deleted): [Note: Proposed text should be in legislative format; i.e., use underscore to denote wording to be inserted (inserted wording) and strike-through to denote wording to be deleted (~~deleted wording~~).]

4. Statement of Problem and Substantiation for Proposal: (Note: State the problem that would be resolved by your recommendation; give the specific reason for your Proposal, including copies of tests, research papers, fire experience, etc. If more than 200 words, it may be abstracted for publication.)

5. Copyright Assignment

(a) I am the author of the text or other material (such as illustrations, graphs) proposed in the Proposal.

(b) Some or all of the text or other material proposed in this Proposal was not authored by me. Its source is as follows: (please identify which material and provide complete information on its source)

I hereby grant and assign to the NFPA all and full rights in copyright in this Proposal and understand that I acquire no rights in any publication of NFPA in which this Proposal in this or another similar or analogous form is used. Except to the extent that I do not have authority to make an assignment in materials that I have identified in (b) above, I hereby warrant that I am the author of this Proposal and that I have full power and authority to enter into this assignment.

Signature (Required) _____

PLEASE USE SEPARATE FORM FOR EACH PROPOSAL

Mail to: Secretary, Standards Council · National Fire Protection Association
1 Batterymarch Park · Quincy, MA 02169-7471 OR

Fax to: (617) 770-3500 OR Email to: proposals_comments@nfpa.org