

	Sanders Unified School District, #18 Amendment #2		I-40 & Hwy 191 Sanders, AZ 86512
	IFB: 18-24-18 PROJECT: Replacement of Two Cooling Towers at Sanders Elementary	Page 1 of 1	

May 8, 2018

This Amendment is released to all interested parties,

1. A reminder that the bids are due on **May 18, 2018, at 11:00 AM (Mountain Savings Time)**. That would be 10:00 AM in Phoenix.

2. It states on page 32 note #2, that it requires a C-49 license. This is an industrial refrigeration license which means it deals with food. Is there a reason for this specific license?

[LSW Response] – The vendor is only required to have the appropriate Commercial License to do the scope of work.

3. Is schedule 40 steel pipe with groove ends and fittings approved?

[LSW Response] – Schedule 40 steel pipe with groove ends and fittings are acceptable for the condenser piping on this project.

4. Could you confirm who the contact is for the controllers?

[LSW Response] – Page 6 of the drawings, #J, 1. “THIS CONTRACTOR IS TO CONTRACT WITH THE OWNER'S CURRENT TRANE CONTROLS REPRESENTATIVE (CONTACT TRANE, DIEGO DISDIER 480.518.1628) TO DISCONNECT & RECONNECT THE CONTROLS.”

DIEGO DISDIER 480-518-1628

5. Please remember to sign your offer sheet and don't be late to deliver you bid to the District Office.
6. Remember to acknowledge this and all other Amendments.
7. All other terms and conditions remain the same.
8. End of Amendment #2.