

	Sanders Unified School District, #18 Amendment #3		I-40 & Hwy 191 Sanders, AZ 86512
	IFB: 18-24-18 PROJECT: Replacement of Two Cooling Towers at Sanders Elementary	Page 1 of 1	

May 8, 2018

This Amendment is released to all interested parties,

1. A reminder that the bids are due on **May 18, 2018, at 11:00 AM (Mountain Savings Time)**. That would be 10:00 AM in Phoenix.

2. Will the system be off line to allow replacement of both towers together?

LSW Response:

The schedule of construction for this project has been set so that the mechanical system can be off and both fluid coolers replaced together.

3. The job scope indicates replacement of steel I-beam support structures, however the existing towers are not set upon a raised steel I-beam structure, is there a requirement for the new ones to be?

LSW Response:

The existing fluid coolers are currently setting on I-beams which are setting on the existing exterior concrete slab. These I-beam supports are to be replaced with new matching the new fluid coolers (refer to Keyed Note #1 on sheet M2.2).

4. Does the steel groove lock piping for the condenser loop require replacement? We did not see it called out on the scope.

LSW Response:

The exterior condenser piping is to be replaced with new per the drawings (refer to sheets M1.1 and 2.1)

5. Please remember to sign your offer sheet and don't be late to deliver you bid to the District Office.
6. Remember to acknowledge this and all other Amendments.
7. All other terms and conditions remain the same.
8. End of Amendment #3.