

Seaside School District 10

Lead Testing Results in a Water Analysis Report 8/29/16

Results for lead testing in water are provided in an *Analysis Report* from Alexin Analytical ORELAP Accredited Lab# OR-100013. Use the information below to determine from which location each sample was taken, as well as the type of sample taken.

Location Number: This number designates the site from which the sample was taken (GES=004 Gearhart Elementary, SHE=005 Seaside Heights Elementary, BMS=006 Broadway Middle School, SHS=007 Seaside High School).

Sample Number and Collection Site:

- 1 SHS Concession Faucet
- 2 SHS Concession Faucet
- 3 SHE Rm B4 Fountain
- 4 SHE W Hall Fountain
- 5 SHE Boys Locker Fountain
- 6 SHE Girls Locker Fountain

Outlet Type:	WF	Water Fountain (not chilled)
	WC	Water Fountain (chilled)
	KF	Kitchen Faucet
	CF	Custodial Faucet
	HB	Hose Bib

Sample Type:	P	Primary Sample (first draw)
	F	Flush Sample (30 second pre-flush)

For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.



Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number:

Client Contact Information		Invoicing Information	
Company/Client Name: <u>Seaside School District</u>		Accounts Payable Contact:	
Address: <u>1801 S Franklin</u>		Mailing Address:	
City/State/Zip: <u>Seaside, OR 97138</u>		City/State/Zip:	
phone: <u>503-738-3471</u>		phone:	
fax or email: <u>503-738-3471</u>		fax or email:	

SAMPLING INFORMATION

Project Name: _____ P.O. #: _____ PWSID #: _____

Project #: _____ Permit #: _____

Send results to OR State Health Division? (Please circle) Yes No

Lab ID <small>Lab use only</small>	Sample Identification	Please enter a unique ID per line for each separate sample	Date Collected	Time Collected	Sample Matrix*	# of cont. rec'd	Analysis Requested**	
							Begin	End (if comp.)
	1-007-KF-P		8-4-16	806			Lead	FTM ATTACHED
	2-007-KF-F		8-4-16	808				
	3-005-WF-F		8-4-16	840				
	4-005-WF-F		8-4-16	847				
	5-005-WF-F		8-4-16	851				
	6-005-WF-F		8-4-16	854				

Sample Specific Notes/Field Data
for each WW sample, specify Grab / Composite
for each DW sample, specify Raw / Treated,
Source / Distribution, Single / Combined
WHERE APPLICABLE

Relinquished By (print): Glendon Ely Company: Seaside School Dist Date/Time: 8/4/16 Signature: [Signature]

Relinquished By (print): _____ Company: _____ Date/Time: _____ Signature: _____

Received By: _____ Company: _____ Date/Time: _____ Signature: _____


Received By: _____ Company: _____ Date/Time: _____ Signature: _____

The most current revision of SOP-10-003 was used when these samples were collected

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

Temp. on receipt: _____ °C Containers Intact? Y N ID: TRM-10-_____

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 08/29/2016
Received: 08/10/2016
Sampled By:
Work Order: 6223058

**C
L
I
E
N
T**
Seaside School District
Attn: Glen Ely
1801 S Franklin
Seaside OR, 97138
Phone: (503) 791-5650

Project:
Project # : N/A
PWSID # :

Sampling Location:

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6223058-01	Sample Name: 1-007-KF-P Sampled: 8/4/16 8:06		Matrix: Water				
+Lead	1030	EPA 200.9	18.7	ppb	2.0	20 ppb	08/26/16 17:49
6223058-02	Sample Name: 2-007-KF-F Sampled: 8/4/16 8:08		Matrix: Water				
+Lead	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	08/26/16 17:49
6223058-03	Sample Name: 3-005-WF-F Sampled: 8/4/16 8:40		Matrix: Water				
+Lead	1030	EPA 200.9	22.5	ppb	2.0	20 ppb	08/26/16 17:49 MCLE
6223058-04	Sample Name: 4-005-WF-F Sampled: 8/4/16 8:47		Matrix: Water				
+Lead	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	08/26/16 17:49
6223058-05	Sample Name: 5-005-WF-F Sampled: 8/4/16 8:51		Matrix: Water				
+Lead	1030	EPA 200.9	8.3	ppb	2.0	20 ppb	08/26/16 17:49
6223058-06	Sample Name: 6-005-WF-F Sampled: 8/4/16 8:54		Matrix: Water				
+Lead	1030	EPA 200.9	8.2	ppb	2.0	20 ppb	08/26/16 17:49

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.